



**DEPARTMENT OF COMMUNITY MEDICINE
INSTITUTE OF MEDICAL SCIENCES
BANARAS HINDU UNIVERSITY
VARANASI - 221 005**



Phone: 0542-6703298

email: cm.ims.bhu@gmail.com

WATER ANALYSIS REPORT FOR DRINKING WATER*

Name and Address : Raj Ghat Besant School
Date of Collection : 27.01.2022
Date of Receipt : 27.01.2022
Place of Collection : Rajghat Besant School.
Source of Collection : Besant School [Tanky water.]

OBSERVATION

PHYSICAL ANALYSIS	NORMAL VALUE	RESULT
Colour	Colour less	Colour less
Odour	Odour less/ Pungent	Odour less
Sedimentation	Transparent	Transparent
CHEMICAL ANALYSIS		
pH	7.0-7.5	7.0
Residual Chlorine	0.5 ppm	Nil
Chloride	15 mg/liter	02mg/liter
Hardness	300 mg/liter	40 mg per liter
Nitrite	NIL	Nil
Nitrate	NIL	Nil
BACTERIOLOGICAL TEST		
M.P.N. Count	NIL	Nil
RESULT		
Satisfactory	0-1	Satisfactory
Suspicious	3-10	
Unsatisfactory	> 10	

Remark: Water sample collected by party it self.

Lab. In charge

Dept. of Community Medicine
IMS, BHU, Varanasi - 05
Institute of Medical Sciences
Banaras Hindu University